

# LPCB & Civil Defense Certificate

- Certificate of LPCB Approval FIRE GUARD 1000 Plus
- Civil Defense Certificate



## Doha Cables - Qatar L.L.C.

### Office

3<sup>rd</sup> Floor, KIA Motors Showroom Bldg.,  
Al Rayyan Road, Al Sadd,  
P.O. Box 22487, Doha, Qatar  
Tel. : (+974) 4455 30 43  
Fax : (+974) 4455 30 49  
Email: info@dohacables.com

### Factory

MIC Community Area,  
Mesaieed, Qatar

[www.dohacables.com](http://www.dohacables.com)

THE FIRST CABLE MANUFACTURER IN QATAR

## Certificate of Product Approval

Certificate Number: 1281a

Issue: 01

### Doha Cables

MIC Community Area  
Mesaieed 22487  
QATAR



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

#### Product(s)

Cable Types as listed below:  
FIRE GUARD 1000 PLUS  
See Certificate Appendix for details

#### Standard(s) (see Appendix for details)

BS 7846:2009 Cat F2 & F120  
EN 50267-2-2:1999  
BS 8519:2010

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

David Hoare  
Certification Scheme Manager

17 February 2015  
Date of Issue

17 February 2015  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



## Appendix to Certificate No: 1281a Doha Cables

**Issue: 01**

Product name				LPCB Ref. No.
FIRE GUARD 1000 PLUS				1281a/01
Nominal csa of conductor (mm <sup>2</sup> )	Core Construction	BS 7846	EN 50267-2-2	BS 8519
50	4 <sup>(1)</sup>	F2 <sup>(2)</sup> & F120 <sup>(3)</sup>	Complies	Category 3 <sup>(3)</sup>
70	4 <sup>(1)</sup>	F2 <sup>(2)</sup> & F120 <sup>(3)</sup>	Complies	Category 3 <sup>(3)</sup>
95	4 <sup>(1)</sup>	F2 <sup>(2)</sup> & F120 <sup>(3)</sup>	Complies	Category 3 <sup>(3)</sup>
120	4 <sup>(1)</sup>	F2 <sup>(2)</sup> & F120 <sup>(3)</sup>	Complies	Category 3 <sup>(3)</sup>
150	4 <sup>(1)</sup>	F2 <sup>(2)</sup> & F120 <sup>(3)</sup>	Complies	Category 3 <sup>(3)</sup>
185	4 <sup>(1)</sup>	F2 <sup>(2)</sup> & F120 <sup>(3)</sup>	Complies	Category 3 <sup>(3)</sup>
240	4 <sup>(1)</sup>	F2 <sup>(2)</sup> & F120 <sup>(3)</sup>	Complies	Category 3 <sup>(3)</sup>
300	4 <sup>(1)</sup>	F2 <sup>(2)</sup> & F120 <sup>(3)</sup>	Complies	Category 3 <sup>(3)</sup>

Uo/U 600/1000V

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

David Hoare  
Certification Scheme Manager

17 February 2015  
Date of Issue

17 February 2015  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)




## Appendix to Certificate No: 1281a Doha Cables

Issue: 01

### Notes:

1. Stranded conductors only.
2. In meeting the requirements of BS 7846:2009 Category F2, the FIRE GUARD 1000 PLUS cables met the requirements for smoke density to EN 61034-2:2005, fire resistance to BS 6387:2013 CWZ and achieved less than 0.5%HCl on the insulation, tapes, filler, bedding and outer covering when tested in accordance with EN 50267-2-1:1999.
3. In meeting the requirements of BS 7846:2009 Category F120, the FIRE GUARD 1000 PLUS cables listed met the requirements for 120 minutes fire resistance to BS 8491:2008 and therefore BS 8519:2010 Category 3 for power cables.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

David Hoare  
Certification Scheme Manager

17 February 2015  
Date of Issue

17 February 2015  
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



bre

بسم الله الرحمن الرحيم

التاريخ: ٢٠١٥/٠٢/١٢  
الموافق: ١٤٣٦/٠٤/٢٣  
رقم الطلب: ١٨٧٦٢٣



وزارة الداخلية  
الإدارة العامة للدفاع المدني  
إدارة الوقاية

شهادة الإدارة العامة للدفاع المدني

نوع الشهادة: شهادة عدم ممانعة استيراد معدات و اجهزة و مواد نظام الوقاية و مكافحة الحريق  
رقم الشهادة: ٩١٠٣١٥٠٠٠١٠٠٠٠٠٠٠  
رقم رخصة البناء: ٦٥٢٤٩  
اسم المرخص له: فيصل قاسم فيصل ال ثاني وشركاه  
اسم المالك: .  
الاسم التجاري: الدوحة للكابلات - قطر  
رقم الوحدة: .....  
الهاتف الجوال: ٧٧٣٩٠٧٧٧  
صندوق البريد: ٧٧٣٩٠٧٧٧  
البريد الالكتروني: sanaa.shehata@hotmail.com  
رقم التسجيل التجاري: ٤٠٣٤٤  
هاتف المكتب: ٧٧٣٩٠٧٧٧  
رقم الفاكس: ٤٤٥٥٣٠٤٩


رقم المنطقة: ٩١  
رقم قطعة الأرض: ١  
رقم الشارع: ٣١٥  
اسم الشارع: البدع  
رقم المبنى:

تفاصيل الشهادة

تمت الموافقة على المنتج (FIRE RESISTANT CABLES) وذلك حسب التقرير الفني الصادر بتاريخ ٢٠١٥/٠٤/٠٨ والمرفق طيه صورته منه

ملاحظة:-

( يرجى الإطلاع على الإشتراطات في خلف الشهادة والإلتزام بها )



توقيع مدير إدارة الوقاية:  
الإدارة العامة للدفاع المدني

تاريخ انتهاء الشهادة ٢٠١٧/٠٤/١٢

تاريخ إصدار الشهادة ٢٠١٥/٠٤/١٣

توقيع الضابط المختص:  
إدارة الوقاية

